



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.efectis.com

DECLARATION OF TEST RESULTS

No: EEA – 1900 – 0081 – REV2

The fire resistance test was carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 29.08.2019 in accordance with the test standard:

DIN 4102-12:1998

CABLE SYSTEM – SIGNAL CONTROL CABLES FIXED ON CABLE TRAYS AND CABLE LADDERS “GERPA”

FIRE RESISTANCE RESULTS					
CODE	PRODUCT TYPE	RESULTS	CODE	PRODUCT TYPE	RESULTS
GE-MC1-20-A50	Cable Ladder	E90	GE-KT2-10-A110	Cable Tray	E90
GE-MC1-10-A50	Cable Ladder	E90	GE-KT2-60-A110	Cable Tray	E90
GE-KT2-10-A75	Cable Tray	E90	GE-KT2-10-A85	Cable Tray	E90
GE-KT2-10-A50	Cable Tray	E90	GE-KT2-40-A85	Cable Tray	E90
GE-KT2-20-A60	Cable Tray	E90	GE-MC1-25-A50	Cable Ladder	E90
GE-KT2-10-A60	Cable Tray	E90	GE-MC1-25-A70	Cable Ladder	E90
GE-MC2-30-A110	Cable Ladder	E90	GE-MC1-30-A50	Cable Ladder	E90
GE-KT2-40-A50	Cable Tray	E90	GE-KT2-60-A60	Cable Tray	E90
GE-KT2-10-A100	Cable Tray	E90	GE-MC2-60-A110	Cable Ladder	E90
GE-KT2-20-A100	Cable Tray	E90	GE-KT2-10-A75	Cable Tray	E90
GE-KT2-30-A110	Cable Tray	E90	GE-KT2-20-A75	Cable Tray	E90

Placed on the market by: GERPA ELEKTRİK TEKSTİL SAN. VE TİC. A.Ş.
Yeşilbağlar Mahallesi Selvili Sk. Helis Beyaz Ofis Sit. A Blok Apt.
No:2/1/25, Pendik, İstanbul / TURKEY

Manufactured by: GERPA ELEKTRİK TEKSTİL SAN. VE TİC. A.Ş.
IMES OSB 8. Cad. No:16 Çerkeşli Mah. 41455
Dilovası, Kocaeli / TURKEY

Ali BAYRAKTAR
Laboratory Manager
03.11.2021



This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: RFTR19192.